

## RFI RESPONSE

---

RFI: 1 and 2

From: Winter Construction

Date: 3/17/2021

Project Name: GA Tech Yunker Lab- Cherry Emerson

HERA Project No.: 20176.00

Owner Project No.: 0360-2020

In Attendance:

Copies To: sent via email

---

1. Laboratory Equipment The width under the fume hood is just under 72". The requested two 36" replacement specialty cabinets would not be able to fit without adjusting the adjacent casework. Please confirm whether we can move the casework down to accommodate 72", ((2) 36" cabinets).

Response: Keep the 36" Acid cabinet and reduce the flammable cabinet to a 34" wide cabinet.

2. Please indicate if the following fixtures are new or existing:

a. Elevation 1/QL-501 Room 230 N: VAC-1-1, CA-1-1, CO2-1-1, CO2-1-1, CA-1-1, VAC-1-1

b. Elevation 6/QL-501 Room 232 E: CA-1-1, VAC-1-1, CO2-1-1

Response: Yes, those are new gas outlets.

Name  
Date  
Page 2

Respectfully submitted,

This represents our understanding of the discussion. Please submit any comments or changes to these notes to HERA within 7 days.