



***The Winter Construction Company***

5616 Peachtree Road

Chamblee, Georgia 30341

Telephone: 404/588-3300

Fax: 404/588-0572

July 29, 2021

Request For Clarifications:

Georgia Tech Grad Office and Lobby Renovation – 7/14/21 Issued for Construction Drawings

Attn: Fenella Bryant  
Georgia Institute of Technology  
fenella.bryant@facilities.gatech.edu

From: Winter Construction, Kira Alford  
5616 Peachtree Road  
Chamblee, GA 30341

RFI's:

5. Rooms 212 & 214/216 Door Frame Clarification

Regarding the new openings for Rooms 212 & 214/216, are the door frames for these 2 openings hollow metal frames or aluminum frames? The door schedule indicates that they are hollow metal, but Sheet A.101 Floor plan keynote 17 states storefront system to match existing break room storefront system.

Rooms 212 & 214/216 shall be hollow metal per 1/A.601 and A.820.