



The Winter Construction Company

5616 Peachtree Road

Chamblee, Georgia 30341

Telephone: 404/588-3300

Fax: 404/588-0572

August 04, 2021

Request For Clarifications:

Georgia Tech Grad Office and Lobby Renovation – 7/14/21 Issued for Construction Drawings

Attn: Fenella Bryant
Georgia Institute of Technology
fenella.bryant@facilities.gatech.edu

From: Winter Construction, Kira Alford
5616 Peachtree Road
Chamblee, GA 30341

RFI's:

6. Referencing General Note B on sheet A.101, please provide the product specification for the window coverings needed for the exterior windows of the building.
BALI CLASSIC / 1" ALUMINUM HORIZONTAL / 065 / ALMOST WHITE GLOSS, .006" SLAT OPTION,
7. Referencing Detail 2/A.601, please confirm if PL-1 is to be installed above the 36" millwork coffee counter. Please see the below (Markup 1 – shaded red) for your reference. *CORRECT. PL-1 IS TO BE INSTALLED ABOVE THE 36" TALL MILLWORK COUNTER PER THE ELEVATION. MILLWORK TO BE INSTALLED ON MDF SUBSTRATE PER MANUFACTURER RECOMMENDATION.*
8. Referencing the Door Notes on A.820 please advise on the below.
 - a. Note 4/A.820, please specify which doors are considered Egress doors and need panic hardware.
 - b. Note 2/A.820, please provide the door hardware specification needed to meet Georgia Tech Standards
REFER TO THE DOOR HARDWARE SET NUMBERS FOR HARDWARE. REFER TO SPECIFICATION SECTION 08 7100 FOR DOOR HARDWARE.
9. Referencing the Note 4/A.501, please clarify if the specified cove light fixtures for Lobby A001 are to be installed in a gyp soffit or be exposed.
THE LIGHT FIXTURE IS EXPOSED PER THE DRAWING, REFER TO LIGHTING SCHEDULE.

RFI 7 – Markup 1

