

## **Addendum #1**

**GT RP Halcyon, LLC  
c/o AJC Consulting, LLC**

**May 29, 2020  
Halcyon Ph 2 Buildings 1100, 1300 & 1400**

## **ADDENDUM #1**

Please find the following supplemental information for the proposal due 6/4/20.

1. Updated Civil documents per County permit review comments:
  - a. Civil plan adjustments dated 05/22/20 per County Permit Review Comments:  
Revisions to the bid set dated 4/24/20 are clouded in red on sheets: C1-00, C2-00, C2-01, C2-02, C2-30, C4-00, C4-10, C6-10 & L1-01. All other sheets unchanged except date of issue.
2. Existing Condition utility survey and profiles for contractors use:
  - a. TPA Utility Survey 033020 with test pit locations.
  - b. Test pit data 040120.
3. Correction to referenced detail – Alternate #11 – reference plan note 11 S1.01 / detail 3/S-3.01 and Alternate #9 for polished slabs. Alternate expansion joint material such as foam or bituminous expansion vs preformed is acceptable for polished slab with urethane sealant installed as part of the polishing process at all SOG control joints within polished slab areas and to be included in Alternate #9.

End of Addendum #1