

CONTOUR ENGINEERING

Memorandum

Date:	March 16, 2020
Project Name:	Halcyon Buildings 1100, 1300, 1400
Location:	Alpharetta, Forsyth County, GA
Client:	GT RP Halcyon, LLC
Client Contact:	Alexander King
Project No.:	G20HAL01

As requested, Contour has re-evaluated the seismic site classification for the subject site based on the improvement of the subsurface soils via installation of aggregate piers below the foundation elements. Based on the subsurface data collected and the ground improvement provided by installation of aggregate piers, a seismic Site Classification of "C" may be used provided that aggregate piers are installed beneath all foundation elements to a minimum depth of twenty-five (25) feet below the bottom of foundation elevations.

Should you have any questions concerning the content of this memorandum or need any additional information, please do not hesitate to contact us.

Sincerely,
Contour Engineering, LLC



Andrew M. Rebeiz
Project Engineer



Jack M. Rebeiz, P.E.
Principal Engineer

