



The Winter Construction Company

5616 Peachtree Road

Chamblee, Georgia 30341

Telephone: 404/588-3300

Fax: 404/588-0572

July 12, 2021

Request For Clarifications:
Solvay N2004 Exhaust Fan

Attn: Kami Hopkinson
Solvay
Kami.hopkinson@solvay.com

From: Winter Construction, Kira Alford
5616 Peachtree Road
Chamblee, GA 30341

RFI's:

1. Sheet M402 discusses a VFD operation of the Exhaust Fan. I do not see this in the electrical drawings. Is this integral to the exhaust fan itself?

Electrical Response: The VFD is not integral to the exhaust fan. It is a separate item. The electrical disconnect switch shown on sheet E-1 feeds the VFD and is wired ahead of the VFD.